




Regional Water Testing Laboratory
Address: 4/4 Sanjay Place U.P. JalNigam(Rural) Agra, 282002



TEST REPORT					
Report No:	UPJN/AGR/26/04/803	Issue Date:	10/04/2026	Page No	1/2
Customer Details					
Office Name and Address	Manager ,Bhartiya Vidhya Bhawan School Dhandhupura Road, Agra				
Ref Letter No & Date	BVBS/04-JN/2026 DATE-08/04/2026				
Basic details of sample					
		Block/City			
District	Agra	Village/city	Dhandhupura		
Gram Panchayat	-	Location	Bhartiya Vidhya Bhawaan School		
Water Source	RO Water	Sample No.	01		
Quantity of Sample	1 lt.	Date of Collection	08/04/2026		
Receiving Date	08/04/2026	S. Collector	Mr.Shailendra		
Sample Depositor	Mr.Shailendra	Sampling Method	As per IS 17614: Part 1: 2021		
Analysis Start Date	08/04/2026	Analysis Completion Date:	11/04/2026		
Technical Data of Analysis					
S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130)
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.54	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity NTU	0.828	1	5	IS 3025 (Pt 10):1984 (Nephelometric Method)
3	Total Dissolved Solid mg/L	197	500	2000	IS 3025 (Pt 16):1984 (Gravimetric Method)
4	Fluoride mg/L	0.868	1	1.5	APHA 24 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	32	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	42	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	12	250	1000	IS 3025 (Part 32):1988 (Argentometric method)
8	Iron mg/L	--	1	1	APHA 24 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	02	200	400	APHA 24 rd Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Calcium mg/L	18	75	200	IS 3025 (Part 40):1991(EDTA Titrimetric Method)
11	Magnesium mg/L	6.048	30	100	IS 3025 (Part 46):1994(Volumetric Method)

Manager
Bhartiya Vidhya Bhawan School
Dhandhupura Road, Agra

1


Principal
Bhartiya Vidhya Bhawan School
Dhandhupura Road, Agra





Regional Water Testing Laboratory


Address: 4/4 Sanjay Place U.P. JalNigam(Rural) Agra, 282002



12	Color (Hazen)	2	5	15	APHA 24 th Edition Color 2120 B (Visual Comparison Method)
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 1984 (Qualitative Method)
14	Nitrate (mg/l)	Nil	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.


(Amita Devi)
Authorized Signatory
Testing Lab In charge

Laboratory Contact details
Mob. (8630905287)

-----End of Report-----

Manager
Bhartiya Vidhya Bhawan School
Dhandhupura Road, Agra

Principal
Bhartiya Vidhya Bhawan School
Dhandhupura Road, Agra

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/AGR/26/04/803

Dated: 10/04/2026

It is certified that an inspection team headed by Mr. BIPIN AGARIYA (A.E.) (Name of Officers with designation) from U.P. Jal Nigam (Rural), Agra, inspected the BHARTIYA VIDHYA BHAWAN SCHOOL, DHANDHUPURA ROAD, AGRA (Name & Address of the school) on 08/04/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no UPJN/AGR/26/04/803 dated 10/04/2026 of Regional Level Water Analysis Laboratory (UP JAL NIGAM) certified that the BHARTIYA VIDHYA BHAWAN SCHOOL, DHANDHUPURA ROAD, AGRA (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year from issue date

सहायक अभियंता
खण्ड कार्यालय
उ०प्र० जल निगम (ग्रामीण)

Signature with Seal: उ०प्र० जल निगम (ग्रामीण)

Name: Mr. Bipin Agariya आगरा

Designation: Assistant Engineer

Name & Address of the Office / Department: Regional Level Water Analysis Laboratory


To

BHARTIYA VIDHYA BHAWAN
SCHOOL, DHANDHUPURA ROAD,
AGRA,



Manager

Bhartiya Vidhya Bhawan School
Dhandhupura Road, Agra



Principal

Bhartiya Vidhya Bhawan School
Dhandhupura Road, Agra